

**Report  
On  
Green Audit  
At  
The International Institute of Information Technology (I<sup>2</sup>IT), Pune**



INNOVATION & LEADERSHIP  
[www.isquareit.edu.in](http://www.isquareit.edu.in)

**(Year 2022-23)**

Prepared by  
**Nutan Urja Solutions**  
A 703, Balaji Witefield, Near Sunni's World,  
Sus Road, Sus, Pune 411 021  
Phone: 83568 18381. Email: [nutanurja.solutions@gmail.com](mailto:nutanurja.solutions@gmail.com)



## Contents

Acknowledgement .....	3
Executive Summary .....	4
Abbreviations .....	6
1. Introduction .....	7
1.1 Objectives.....	7
1.2 Audit methodology.....	7
2. Building Survey .....	8
3. Study of Electrical Energy Consumption .....	9
4. Carbon Foot printing.....	11
5. Study of Usage of Alternate Energy .....	13
6. Study of Rain Water Harvesting .....	15
7. Study of Waste Management .....	16
7.1 Solid Waste Management.....	16
7.2 e-Waste Management .....	16
8. Study of Green Practices.....	17
8.1 No of students who don't use own Vehicle for coming to Institute.....	17
8.2 Usage of Public Transport.....	17
8.3 Pedestrian Friendly Roads.....	17
8.4 Plastic Free Campus .....	17
8.5 Paperless Office.....	18
9. Green Landscaping with Trees and Plants .....	19
10. Recommendations.....	21



## Acknowledgement

We at Nutan Urja Solutions, Pune, express our sincere gratitude to the management of The International Institute of Information Technology (I<sup>2</sup>IT), Pune for awarding us the assignment of Green Audit of their college premises.

We are also thankful to various Head of Departments & other Staff members for helping us during the field measurements.

We hope that the recommendations stated in this report will be useful and worthy of discussions to take things forward to help implementation of energy conservation measures and green practices. While we have made every attempt to adhere to high quality standards, in both data collection and analysis through the report, we would welcome your suggestions so as to improve upon this report further.



## Executive Summary

Green Audit of The International Institute of Information Technology (I<sup>2</sup>IT), Pune is conducted by Nutan Urja Solutions, Pune. Based On the audit field study, following important points can be presented.

### 1. Present Energy Consumption

The International Institute of Information Technology (I<sup>2</sup>IT), Pune uses Electrical Energy as the source of Energy for various equipment in the college campus. In the following Table, we present the details of Energy Consumption.

**Table no 1: Details of energy consumption**

Sr no	Parameter	Energy consumed, (Units)	CO2 Emission (MT)
1	Maximum	95,329	76.26
2	Minimum	69,774	55.82
3	Average	81,772	65.42
4	Total	9,81,266	785.01

### 2. Various Measures Adopted for Energy Conservation

1. Usage of STAR Rated ACs at new installations
2. Usage of LED lights at some indoor locations
3. Usage of LED Lights for outdoor lighting.

### 3. Usage of Renewable Energy

The collage has installed 7 kW Solar PV Power Plant. College has also installed 4200 liters capacity solar thermal hot water system.

### 4. Rain Water Harvesting

The College has installed the Rainwater harvesting project, to reduce dependency on municipal corporation water supply.

## 5. Waste Management

The College has already installed a Bio composting Plant, wherein, the bio-degradable waste is composted & is used as fertilizer for the garden.

The internal communication is through emails and there is hardly any generation of e-Waste in the premises.

## 6. Notes and Assumptions

1. Daily working hours-10 Nos
2. Annual working Days-250 Nos
3. Average Rate of Electrical Energy : **Rs 11/- per kWh**



## Abbreviations

CFL	:	Compact Fluorescent Lamp
FTL	:	Fluorescent Tube Light
LED	:	Light Emitting Diode
V	:	Voltage
I	:	Current
kW	:	Kilo- Watt
kWh	:	kilo-Watt Hour
kVA	:	Active Power



## **1. Introduction**

The International Institute of Information Technology (I<sup>2</sup>IT), Pune [pronounced as I Square IT] was established by Late Shri. P. P. Chhabria, Founder Chairman of Finolex Group of Companies, a well-known philanthropist and former President of Maharashtra Chamber of Commerce, Industries and Agriculture (MCCIA). As a world class academy to impart high-end education in Engineering and Technology the Institute has strived to meet the growing needs of the industry. Established on 10 acres of land, this institute equips students to accept challenges in the areas of Information Technology, Engineering and other niche areas of expertise.

### **1.1 Objectives**

1. To study present level of Energy Consumption
2. To Study the present CO<sub>2</sub> emissions
3. To assess the various equipment/facilities from Energy efficiency aspect
4. To measure various Electrical parameters
5. To study Scope for usage of Renewable Energy
6. To study various measures to reduce the Energy Consumption

### **1.2 Audit methodology**

1. Study of connected load
2. Study of various Electrical parameters
3. To prepare the Report with various Encon measures with payback analysis



## 2. Building Survey

1. Square footage / total acres – 10.22 acres
2. Occupancy – 450 nos., Class rooms – 20 nos., Labs – 33, Construction done – 20,463.34 Sq. mtr, free space- 6266.93 Sq. mtr. (Circulation area)
3. Students – a) Boys – 300 . b) Girls – 250
4. Hostel rooms / capacity – a) Boys – 151 nos. Girls – 111 nos.
5. Impervious v/s pervious surface proportion . 51:49.
6. Concrete land/paved surface – 15450 Sq. meters.
7. Garden Land (soil) – 14851 Sq. meters.






### 3. Study of Electrical Energy Consumption

In this chapter, electricity bills are studied for the analysis of electrical energy consumption.

**Table no 3.1: Summary of electricity bills**


No	Month	Energy (kWh)	Bill Amount (Rs)
1	Jun-23	69,774	10,53,884
2	May-23	73,949	11,08,659
3	Apr-23	70,050	10,74,846
4	Mar-23	92,567	13,68,986
5	Feb-23	72,850	11,03,557
6	Jan-23	81,062	12,18,237
7	Dec-22	87,956	13,10,532
8	Nov-22	81,688	12,27,027
9	Oct-22	81,558	12,36,824
10	Sep-22	95,329	14,21,582
11	Aug-22	90,002	13,37,242
12	Jul-22	84,481	12,62,260
	<b>Total</b>	<b>9,81,266</b>	<b>1,47,23,636</b>

Variation in energy consumption is as follows,



**Figure 3.1: Month wise energy consumption**

Monthly variation in electricity bill is as follows,



**Figure 3.2: Month wise electricity bill**

Key observations of electricity bill are as follows,

**Table no 3.2: Key observations**

Sr no	Parameter	Energy consumed, (Units)	CO2 Emission (MT)
1	Maximum	95,329	76.26
2	Minimum	69,774	55.82
3	Average	81,772	65.42
4	Total	9,81,266	785.01

#### 4. Carbon Foot printing

1. A **Carbon Foot print** is defined as the Total Greenhouse Gas emissions (CO<sub>2</sub> emissions), emitted due to various activities. In this we compute the emissions of Carbon-Di-Oxide, by usage of the various form of Electrical Energy used by the College for performing its day to day activities

##### 2. Basis for computation of CO<sub>2</sub> Emissions:

The basis of Calculation for CO<sub>2</sub> emissions due to Electrical Energy is as under

- 1 Unit (kWh) of Electrical Energy releases **0.8 Kg of CO<sub>2</sub>** into atmosphere.

Based on the above Data we compute the CO<sub>2</sub> emissions which are being released in to the atmosphere by the College due to its Day to Day operations


We herewith furnish the details of various forms of Energy consumption as under

**Table 4.1: Month wise Consumption of Electrical Energy & CO<sub>2</sub> Emissions**

No	Month	Energy Consumed, kWh	CO <sub>2</sub> Emissions, MT
1	Jun-23	69,774	55.82
2	May-23	73,949	59.16
3	Apr-23	70,050	56.04
4	Mar-23	92,567	74.05
5	Feb-23	72,850	58.28
6	Jan-23	81,062	64.85
7	Dec-22	87,956	70.36
8	Nov-22	81,688	65.35
9	Oct-22	81,558	65.25
10	Sep-22	95,329	76.26
11	Aug-22	90,002	72.00
12	Jul-22	84,481	67.58
	<b>Total</b>	<b>9,81,266</b>	<b>785.01</b>

In the following Chart we present the CO<sub>2</sub> emissions due to usage of Electrical Energy.





**Figure 4.1: Month wise CO2 Emission**

## 5. Study of Usage of Alternate Energy

In this Chapter, we compute the percentage of Usage of Alternate/Renewable Energy to Annual Energy Requirement of the College. The College has installed Roof Top Solar PV System. The Installed Capacity of Solar PV Plant is **7 kWp**. Also, college has installed 7 nos of solar thermal hot water systems with 600 liters capacity each. Total installed solar thermal hot water capacity is 4200 liters.

**Table 5.1: Computation of % Usage of Alternate Energy to Annual Energy Requirement**

No	Particulars	Value	Unit
1	Annual Energy Purchased from MSEDCL	981,266	kWh/Annum
2	Energy Generated by Roof Top Solar PV System	10,500	kWh/Annum
3	Total Energy Requirement of College	991,766	kWh/Annum
4	% of Usage of Alternate Energy to Annual Energy Requirement	1.05	%



**Figure 5.1: Photograph of Solar PV plant**




**Figure 5.2 :** Photograph of solar thermal hot water system

## 6. Study of Rain Water Harvesting

The College has already installed Rain Water Harvesting project, wherein the rain water falling on the terrace is collected and through pipes it is fed to underground Water Storage tank. This stored water is then reused for domestic purpose.

### Photograph of Rain Water Harvesting pipe



## **7. Study of Waste Management**

### **7.1 Solid Waste Management**

The College has already installed a Bio composting Plant, wherein, the bio-degradable waste is composted & is used as fertilizer for the garden.

#### **Photographs of Bio Composting Storage Tanks:**



### **7.2 e-Waste Management**

Here we study the disposal of E-wastes, Non-working computers, monitors and printers. Workshop on Electronic waste management is conducted in college. E waste collected from college is deposited to Ecocentric Management Pvt Ltd.





## **8. Study of Green Practices**

### **8.1 No of students who don't use own Vehicle for coming to Institute**

Out of total students coming to Institute, about 60% students use own Automobile.

### **8.2 Usage of Public Transport**

Student hostels are within the campus. Many students stay there during academic semesters. During the Students transport study, it was revealed that the local students who are residing near areas make use of Public Transport like Municipal Transport local buses, local sharing type auto rickshaws. The average number of students is approximately 20 %. Institute encourages students to not to use automobiles.

### **8.3 Pedestrian Friendly Roads**

The Institute has well defined pedestrian foot paths as to facilitate the easy movement of the students within the campus.

#### **Photograph of Road within campus**



### **8.4 Plastic Free Campus**

The Institute is an active participant in the Government of India's most prestigious project of SWATCHH BHART ABHIYAN. The Institute has displayed boards in the Campus, to make the campus plastic free. Various measures adopted for this purpose are as follows

- Installation of Separate waste bins for Dry waste & wet waste
- Usage of paper tea cups in the Institute canteen
- Display of boards in the campus for Plastic Free campus

### **8.5 Paperless Office**

The internal communication of the Institute is through the Internet. There are hardly any day to day operations, where printing is required.



## 9. Green Landscaping with Trees and Plants

The Institute has beautiful maintained Garden. Data of trees in campus is as follows.

**Table 9.1: Trees in campus**

Sr. No	Tree name	Numbers
1	Ficus	16
2	Badam	12
3	Kalak	150
4	Palm Arka	100
5	Bottle Palm	15
6	Mohguni	70
7	Chapha	17
8	Apta	8
9	Coconut	13
10	Neem	18
11	Australian Jojoba	3
12	Gulmohar	17
13	Tikoma	19
14	Bottle brush	22
15	Shindada	5
16	Pomegranate	2
17	Rudraksha	1
18	Bakula	1
19	Mango	6
20	Lemon	2
21	Vegzara	15
22	Suruchi	12
23	Shevga	4
24	Mosambi	2
25	Custard Apple	3
26	Ramphal	4
27	Christmas	2





**Figure 9.1: Beautiful maintained Garden of college**

## 10. Recommendations

1. Installation of 200kW grid connected PV panel.
2. Plant more indigenous species of trees in and around the campus.
3. Set up sewage treatment plant for waste water treatment.





**Report**  
**On**  
**Environmental Audit**  
**At**  
**The International Institute of Information Technology (I<sup>2</sup>IT),**  
**Pune**



INNOVATION & LEADERSHIP  
[www.isquareit.edu.in](http://www.isquareit.edu.in)

**(Year 2022-23)**

Prepared by

**Nutan Urja Solutions**

A 703, Balaji Witefield, Near Sunni's World,

Sus Road, Sus, Pune 411 021

Phone: 83568 18381. Email: [nutanurja.solutions@gmail.com](mailto:nutanurja.solutions@gmail.com)



## Table of Contents

Acknowledgement .....	3
Executive Summary .....	4
Abbreviations .....	6
1. Introduction .....	7
1.1 Important Definitions: .....	7
1.2 Objectives .....	8
1.3 Audit Methodology: .....	8
1.4 General Details of College .....	8
2. Study of Consumption of Various Resources .....	9
2.1 Variation of Monthly Electrical Energy Consumption .....	10
2.2 Key Inference drawn .....	11
3. Study of Air Pollution .....	12
3.1 Study of Carbon Emission .....	12
3.2 Air pollution from vehicles .....	13
4. Study of Solid Waste Generation .....	14
4.1 Solid waste collection .....	14
4.2 Canteen food wastage .....	14
4.3 E-waste management .....	14
4.4 Paper wastage .....	14
4.5 Bio composting Plant .....	15
5. Study of Liquid Waste .....	16
5.1 Water Usage .....	16
5.2 Disposal of liquid waste .....	16
5.3. Study of Rain Water Harvesting .....	16
6. Recommendations .....	18





## Acknowledgement

We at Nutan Urja Solutions, Pune wish to express our sincere gratitude to the management of The International Institute of Information Technology (I<sup>2</sup>IT), Pune for assigning the work of Environmental Audit of college campus.

We appreciate the co-operation and support extended to our team members during the entire tenure of field study.

We are also thankful to various Head of Departments & other Staff members for helping us during the field measurements.

We are also thankful to all other staff members who helped us during the Measurements at the field and for giving us the necessary inputs to carry out this vital exercise.



## Executive Summary

After the Field measurements & analysis, we present herewith important observations made and various measures to reduce the dependency on Natural resources & reduce the pollution.

The International Institute of Information Technology (I<sup>2</sup>IT), Pune consumes various resources for day to day operations, namely: Air, Water, Electrical Energy & LPG.

### 1. Various Pollution due to College Activities:

- Air pollution: Mainly CO<sub>2</sub> on account of Electricity & LPG Consumption
- Solid Waste: Bio degradable Kitchen Waste, Garden Waste
- Liquid Waste: Human liquid waste

### 2. Present Level of CO<sub>2</sub> Emissions:

Sr no	Parameter	Energy consumed, (Units)	CO2 Emission (MT)
1	Maximum	95,329	76.26
2	Minimum	69,774	55.82
3	Average	81,772	65.42
4	Total	9,81,266	785.01

### 3. The various projects already implemented for Environmental Conservation:

- Usage of Energy Efficient BEE STAR Rated ACs
- Usage of Natural Day light in corridors
- Implementation of Bio Composting pit for disposal of Bio degradable waste
- Implementation of Rain Water Harvesting
- Installation of 7 kW Solar PV Power Plant.
- Usage of solar thermal hot water system with 4200 liters capacity.

### 4. Recommendations:

1. Installation of Bio Gas Generator Plant instead of Bio composting Plant.
2. Installation of Sewage treatment Plant to make campus a Zero Discharge campus.



**5. Notes & Assumptions:**

1. **1 kWh** of Electrical Energy releases **0.8 Kg of CO<sub>2</sub>** into atmosphere
2. 1 kWp Solar PV plant generates 5 kWh/day Electrical Energy for 300 days in an year.



## Abbreviations

AC	: Air conditioner
PES	: Progressive Education Society
CFL	: Compact Fluorescent Lamp
FTL	: Fluorescent Tube Light
LED	: Light Emitting Diode
kWh	: kilo-Watt Hour
Qty	: Quantity
W	: Watt
kW	: Kilo Watt
PF	: Power Factor
M D	: Maximum Demand
PC	: Personal Computer
MSEDCL	: Maharashtra State Electricity Distribution Company Ltd



## 1. Introduction

### 1.1 Important Definitions:

#### 1.1.1 Environment: Definition as per environment Protection Act: 1986

Environment includes water, air and land and the inter-relationship which exists among and between Water, Air, Land and Human beings, other living creatures, plants microorganism and property

#### 1.1.2. Environmental Audit: Definition:

An audit which aims at verification and validation to ensure that various environmental laws are complied with and adequate care has been taken towards environmental protection and preservation

*According to UNEP, 1990, "Environmental audit can be defined as a management tool comprising systematic, documented and periodic evaluation of how well environmental organization management and equipment are performing with an aim of helping to regularize the environment"*

**1.1.3. Environmental Pollutant:** means any solid, liquid and gaseous substance present in the concentration as may be, or tend to be, injurious to Environment.

#### 1.1.4. Relevant Environmental Laws in India: Table No-1:

1927	The Indian Forest Act
1972	The Wildlife Protection Act
1974	The Water (Prevention and Control of Pollution) Act
1977	The Water (Prevention & Control of Pollution) Cess Act
1980	The Forest (Conservation) Act
1981	The Air (Prevention and Control of Pollution) Act
1986	The Environment Protection Act
1991	The Public Liability Insurance Act
2002	The Biological Diversity Act
2010	The National Green Tribunal Act

#### 1.1.5. Some Important Environmental Rules in India: Table No-2:

1989	Hazardous Waste (Management and Handling) Rules
1989	Manufacture, Storage and Import of Hazardous Chemical Rules
2000	Municipal Solid Waste (Management and Handling) Rules
1998	The Biomedical Waste (Management and Handling) Rules
1999	The Environment (Siting for Industrial Projects) Rules
2000	Noise Pollution (Regulation and Control) Rules
2000	Ozone Depleting Substances (Regulation and Control) Rules



2011	E-waste (Management and Handling) Rules
2011	National Green Tribunal (Practices and Procedure) Rules
2011	Plastic Waste (Management and Handling) Rules

#### 1.1.6 National Environmental Plans & Policy Documents: Table No-3:

1.	National Forest Policy, 1988
2.	National Water Policy, 2002
3.	National Environment Policy or NEP (2006)
4.	National Conservation Strategy and Policy Statement on Environment and Development, 1992
5.	Policy Statement for Abatement of Pollution (1992)
6.	National Action Plan on Climate Change
7.	Vision Statement on Environment and Human Health
8.	Technology Vision 2030 (The Energy Research Institute)
9.	Addressing Energy Security and Climate Change (MoEF and Bureau of Energy Efficiency)
10	The Road to Copenhagen; India's Position on Climate Change Issues (MoEF)

#### 1.2 Objectives

1. To study present usage of Natural resources the College is consuming
2. To Study the present pollution sources
3. To study various measures to make the campus Self sustainable in respect of Natural resources
4. To suggest the various measures to reduce the pollution: Air, Water, Noise

#### 1.3 Audit Methodology:

1. Study of College as System
2. Study of Electrical Energy Consumption
3. Study of CO<sub>2</sub> emissions
4. Suggestions on usage of Renewable Energy

#### 1.4 General Details of College

No	Head	Particulars
1	Name of Institution	The International Institute of Information Technology (I <sup>2</sup> IT), Pune
2	Address	P-14, Phase 1, Hinjewadi Rajiv Gandhi Infotech Park, Hinjawadi, Pune, Maharashtra 411057.
3	Affiliation	Savitribai Phule Pune University

## 2. Study of Consumption of Various Resources


The Institute consumes following basic/derived Resources:

1. Air
2. Water
3. Electrical Energy
4. Liquefied Petroleum Gas

Also, college emits following pollutants to environment

1. Human Waste: Solid/ Liquid
2. Kitchen waste
3. Air pollution

We try to draw a schematic diagram for the College System & Environment as under.




Now we compute the Generation of CO<sub>2</sub> on account of consumption of Electrical Energy & LPG as under.

The calculation of electrical energy consumption by college can be given as,

**Table 2.1: Electrical Energy Consumption**

No	Month	Energy (kWh)
1	Jun-23	69,774
2	May-23	73,949
3	Apr-23	70,050
4	Mar-23	92,567
5	Feb-23	72,850
6	Jan-23	81,062
7	Dec-22	87,956
8	Nov-22	81,688
9	Oct-22	81,558
10	Sep-22	95,329
11	Aug-22	90,002
12	Jul-22	84,481
	<b>Total</b>	<b>9,81,266</b>
	<b>Maximum</b>	<b>95329</b>
	<b>Minimum</b>	<b>69774</b>
	<b>Average</b>	<b>81772</b>

## 2.1 Variation of Monthly Electrical Energy Consumption



**Figure 2.1 : Monthly Electrical Energy Consumption**



## 2.2 Key Inference drawn

From the above analysis, we present following important parameters:

**Table 2.2: Variation in Important Parameters**

No	Parameter/ Value	Energy Consumed, kWh
1	Maximum	95,329
2	Minimum	69,774
3	Average	81,772
4	Total	9,81,266

### 3. Study of Air Pollution

In this Chapter, we present the various types of Pollution as under:

#### 3.1 Study of Carbon Emission


The College is using two forms of Energies, namely: Thermal in the form of LPG and Electrical Energy used for day to day operations of the College. The major pollutant on account of above Energy forms is the Carbon Di Oxide.

- 1 unit (kWh) of Electrical Energy emits 0.8 Kg of CO<sub>2</sub> in the atmosphere
- 1 Kg of LPG emits 3 Kg of CO<sub>2</sub> in the atmosphere


In the following Table, we present the CO<sub>2</sub> emissions.

**Table 3.1: Month wise Consumption of Electrical Energy & CO<sub>2</sub> Emissions:**

No	Month	Energy Consumed, kWh	CO <sub>2</sub> Emissions, MT
1	Jun-23	69,774	55.82
2	May-23	73,949	59.16
3	Apr-23	70,050	56.04
4	Mar-23	92,567	74.05
5	Feb-23	72,850	58.28
6	Jan-23	81,062	64.85
7	Dec-22	87,956	70.36
8	Nov-22	81,688	65.35
9	Oct-22	81,558	65.25
10	Sep-22	95,329	76.26
11	Aug-22	90,002	72.00
12	Jul-22	84,481	67.58
	<b>Total</b>	<b>9,81,266</b>	<b>785.01</b>
	Maximum	95,329	76.26
	Minimum	69,774	55.82
	Average	81,772	65.42



In the following Chart we present the CO2 emissions due to usage of Electrical Energy.



**Figure 3.1: CO2 emission due to usage of electrical energy.**

### 3.2 Air pollution from vehicles

Pollution Under Control (PUC) is mandatory for the Vehicles coming in the campus.

The following practices are observed in college premises

1. Staff and student entries are strictly prohibited without wearing of helmets.
2. The campus have dense canopy of indigenous bloomed plants.
3. Most of plants play major role in minimize the air and noise pollution

## **4. Study of Solid Waste Generation**

In this chapter, we study solid waste generated in college and disposal mechanism of solid waste in college.

### **4.1 Solid waste collection**

The garbage collected in college is segregated into wet and dry centrally in campus. Waste bins are placed in college campus for collection of waste.



**Figure 4.1:** Waste bin placed in college for garbage collection

### **4.2 Canteen food wastage**

The students and canteen staff are encouraged to have minimal food wastage. Canteen contractor have food license and shop act certificate. Food waste collected in canteen disposed for vermicomposting pit. The canteen is encouraged for usage of paper tea cups.

### **4.3 E-waste management**

Here we study the disposal of E-wastes, Non-working computers, monitors and printers. Workshop on Electronic waste management is conducted in college. E waste collected from college is deposited to Ecocentric Management Pvt Ltd.

### **4.4 Paper wastage**

The students and office staff are encouraged to work with minimal use of paper. Regular activities of students are digitally monitored. Two sides of paper (back to back) printing method is preferable. The projects reports pages (one Sided) submitted by students was used to avoid the dependence on fresh pages.

#### 4.5 Bio composting Plant

The College has already installed a Bio composting Plant, wherein, the bio-degradable waste is composted & is used as fertilizer for the garden.



**Figure 4.2** Photograph of Bio Composting Processing Tanks

## **5. Study of Liquid Waste**

In this chapter, we study water consumption and wastage.

### **5.1 Water Usage**

MIDC treated water is available for drinking water and the washroom water. In the institute daily above 3 lakh liters water consumption seen. There are total 20 number of water storage tanks are available in institute. There are 34 number of gents toilets and 35 number of ladies toilets.

Drinking water consumption is 10,000 litres per day Drinking water testing done once in 3 month. In rainy season it is done more frequently. RO plant of capacity 500 Litres per hour. 17 Aqua guard filters fitted in campus. Water sample is tested regularly.


### **5.2 Disposal of liquid waste**

At present the most of the liquid waste generated due to day to day operations is drained off to the municipal Corporation through a pipe. Some of the water used in bathrooms of hostel is used for gardening.

We recommend sewage treatment plant in college for water treatment.

### **5.3. Study of Rain Water Harvesting**

The College has already installed Rain Water Harvesting project, wherein the rain water falling on the terrace is collected and through pipes it is fed to underground Water Storage tank. This stored water is then reused for domestic purpose.



**Figure 5.1: Photograph of Rainwater Harvesting**

## 6. Recommendations

In order to reduce the dependency on Natural resources and also in order to reduce the various pollutions arising due to the day to day operations of the College we herewith recommend following recommendations.

- Installation of Bio Gas Generator Plant instead of Bio composting Plant.
- Installation of Sewage treatment Plant to make campus a Zero Discharge campus





**Report  
On  
Energy Audit  
At  
The International Institute of Information Technology (I<sup>2</sup>IT), Pune**



INNOVATION & LEADERSHIP

[www.isquareit.edu.in](http://www.isquareit.edu.in)

**(Year 2022-23)**

Prepared by

**Nutan Urja Solutions**

A 703, Balaji Witefield, Near Sunni's World,

Sus Road, Sus, Pune 411 021

Phone: 83568 18381. Email: [nutanurja.solutions@gmail.com](mailto:nutanurja.solutions@gmail.com)



## Contents

Acknowledgement .....	2
Executive Summary .....	3
Abbreviations .....	5
1. Introduction .....	6
1.1 Objectives .....	6
1.2 Audit Methodology: .....	6
1.3 General Details of College .....	6
2. Study of connected load .....	7
3. Study of Electrical Energy Consumption .....	16
4. Carbon Foot printing .....	18
5. Study of utilities .....	20
5.1 Study of Lighting .....	20
5.2 Air-conditioners .....	20
5.3 Ceiling Fans .....	20
5.4 Water Pumps .....	20
6. Study of usage of alternate energy .....	21
7. Study of usage of LED lighting .....	23
8. Energy conservation proposals .....	24
8.1 Replacement of old fans with STAR Rated fans .....	24
8.2 Installation of 200kW Solar PV panel .....	25
8.3 Summary of Savings .....	26



## Acknowledgement

We at Nutan Urja Solutions, Pune, express our sincere gratitude to the management of The International Institute of Information Technology (I<sup>2</sup>IT), Pune for awarding us the assignment of Energy Audit of their college premises.

We are also thankful to various Head of Departments & other Staff members for helping us during the field measurements.

We hope that the recommendations stated in this report will be useful and worthy of discussions to take things forward to help implementation of energy conservation measures through energy savings. While we have made every attempt to adhere to high quality standards, in both data collection and analysis through the report, we would welcome your suggestions so as to improve upon this report further.



## Executive Summary

After the Field measurements & analysis, we present herewith important observations made and various measures to reduce the Energy Consumption & mitigate the CO<sub>2</sub> emissions. College consumes Energy in the form of Electrical Energy used for various gadgets, Office & other facilities.

### 1. Present Energy Consumption

In the following Table, we present the details of Energy Consumption.

**Table no 2.1: Details of energy consumption**

Sr no	Parameter	Energy consumed, (Units)	CO2 Emission (MT)
1	Maximum	95,329	76.26
2	Minimum	69,774	55.82
3	Average	81,772	65.42
4	Total	9,81,266	785.01

### 2. Energy Conservation Projects already installed

1. Usage of STAR Rated ACs
2. Usage of LED lights at some indoor locations
3. Usage of LED Lights for outdoor lighting.

### 3. Key Observations

1. Usage of LED lights.
2. Usage of star rated equipment.
3. Maintained a good power factor.
4. There are about 1493 Nos old T-8 type fittings which need to be replaced by 20 W LEDs.



#### 4. Percentage of Usage of Alternate Energy

The College has installed a Roof Top Solar PV Plant. The percentage of usage of Alternate Energy to Annual Energy Requirement is 1.05 %.

#### 5. Percentage of Usage of LED Lighting

The College has various Types of Light fittings, namely: LED, FTL & CFL. The percentage of Annual LED Lighting Usage to Annual Lighting requirement works out to be 98 %.

#### 6. Recommendations

Table no 1: Recommendations for energy savings

No	Recommendation	Annual Saving potential, kWh/Annum	Annual Monetary Gain, Rs.	Investment Required, Rs.	Payback period, Months
1	Replacement of 1721 Nos Old Ceiling Fans with STAR rating fans	22,373	246,103	3,741,454	182
2	Installation of 200kW grid connected PV panel	300,000	3,300,000	10,000,000	36
	<b>Total</b>	<b>322,373</b>	<b>3,546,103</b>	<b>13,741,454</b>	<b>47</b>

#### 7 Notes & Assumptions

1. Daily working hours-10 Nos
2. Annual working Days-300 Nos
3. Average Rate of Electrical Energy : Rs 11/- per kWh



## Abbreviations

CFL	:	Compact Fluorescent Lamp
FTL	:	Fluorescent Tube Light
LED	:	Light Emitting Diode
V	:	Voltage
I	:	Current
kW	:	Kilo- Watt
kWh	:	kilo-Watt Hour
kVA	:	Active Power

## 1. Introduction

The International Institute of Information Technology (I<sup>2</sup>IT), Pune [pronounced as I Square IT] was established by Late Shri. P. P. Chhabria, Founder Chairman of Finolex Group of Companies, a well-known philanthropist and former President of Maharashtra Chamber of Commerce, Industries and Agriculture (MCCIA). As a world class academy to impart high-end education in Engineering and Technology the Institute has strived to meet the growing needs of the industry. Established on 10 acres of land, this institute equips students to accept challenges in the areas of Information Technology, Engineering and other niche areas of expertise.

### 1.1 Objectives

1. To study present level of Energy Consumption
2. To Study Electrical Consumption
3. To assess the various equipment/facilities from Energy efficiency aspect
4. To study various measures to reduce the Energy Consumption

### 1.2 Audit Methodology:

1. Study of connected load
2. Study of various Electrical parameters
3. To prepare the Report with various Encon measures with payback analysis

### 1.3 General Details of College

**Table No-1.1: Details of college**

No	Head	Particulars
1	Name of Institution	The International Institute of Information Technology (I <sup>2</sup> IT), Pune
2	Address	P-14, Phase 1, Hinjewadi Rajiv Gandhi Infotech Park, Hinjawadi, Pune, Maharashtra 411057.
3	Affiliation	Savitribai Phule Pune University



## 2. Study of connected load

In this chapter, we present details of various connected electrical equipment and electrical load.

**Table No-2.1: Location wise study of Electrical fittings in various buildings**

No		LED Tube (20W )	CFL	Led Sq. light (36 W)	Led lamp (9W)	Led lamp (22W )	Passag e light (18W)	Fans
	<b>Admin Building</b>							
	<b>Admin Building (Ground Floor)</b>							
1	A-001 (Maintenance)				2			
2	A-002 (Admin Office )				6			2
3	A-003			4	9		7	6
4	A-004 (Electrical & Electronics Lab.)				6	3		6
5	A-005 (Drawing Hall )				7	9		4
6	A-006 (A) (IT - Computer Center)				3	6		4
7	A-006 (B) (Project and R & D)				4	4		4
8	A-007 (Maintenance)				5			2
9	A-008 / 009 (Pantry f& Maintenance)	3			3			
10	A-010 (Classroom)				7	4		5
11	A-011 (A) (Server Room)				3	2		



12	A-011 (B) (Language lab)				0	2		2
13	A-012 (Toilets)	6			6			
14	A-013 (Amin office)				11			2
15	A-014 (Board Room)				16			3
16	A-015 (Principal' Office)				16			1
17	A-016 (Toilet)				1			
18	A-017 (Admin Office )				12			1
19	A-018				3			1
20	A-019 (Maintenance)	1			0			
21	A-020 (Housekeeping Room)	1			0		3	
	<b>Admin Building (First Floor)</b>				0			
22	A - 101(Faculty Room)				2			1
23	A - 102 (Electronics Design Laboratory)				4	9		4
24	A - 103 (Faculty Room)				2			2
25	A - 104 (Digital and VLSI Laboratory)				4	3		3
26	A - 105 (Electronic Devices and Circuits Laboratory)				4	6		4
27	A - 106 (Faculty Office)	2			0			2
28	A - 107 (C.C. E &				5	3		4



	TC)							
29	A-108 (Maintenance)	2			0			
30	A-109 (Toilets)	6			51	11		
31	A -110 (Maintenance)	2			0			
32	A - 111 (Seminar Hall)	10			5	60		
33	A - 112 (Signal Processing Laboratory)				3	4		4
34	A - 113 (Faculty Room)				2	1		1
35	A - 114 (Training & Placement cell)	2			15			2
36	A - 115 (Communication Laboratory)				6	3		3
37	A - 116 (Exam Control Room)				14			2
38	A - 117 (Faculty Room)				17			3
39	A - 118 (Cabin for HoD)	1			4			1
40	A-119 (Maintenance)	1			0			
41	A - 120 (Central Store)	3			0			1
42	A - 121 (Classroom)				3	6		4
43	A - 122 (Classroom)	4			16	6		4
44	A - 123 (President Office)				40			4

	<b>Admin Building (Second Floor)</b>				0			
45	A-201 (Other Office)				1			
46	A - 202 (Microcontroller & Embedded Laboratory)				10	2		3
47	A - 203 (Web technology lab.)				12	4		3
48	A - 204 (Data Analytics lab.)				2	6		6
49	A - 205 (Internet of Things lab.)				2	6		6
50	A - 206 (Programming & Software test lab.)				2	3		3
51	A-207 (Toilets)			1	16			
52	A - 208 (Maintenance)	1			0			1
53	A-209 (Central Computing Facility)				9	4		4
54	A-210 (Object Oriented Programmeing)				3	4		3
55	A-211 (CE - Computer Center)				3	4		3
56	A-212 (A) (Cabin for HoD)	2		2	0	1		1
57	A-212 (B) (Department Office)			2	0	1		1



58	A-212 (C) (Department Office)				0	1		1
59	A-212 (D) (Cabin for HoD)			1	0	1		1
60	A-212 (E) (Department Office / Faculty Room)			1	0	2		1
61	A-213 (Data Structure Laboratory)				3	4		4
62	A-214 (Network Laboratory)				2	4		3
63	A-215 (Faculty Room)				1			2
64	A-216 (Tutorial Room)	2			6			1
65	A-217 (Student association)	3			4	2		3
66	A-218 (Faculty Room)	17			0			1
67	A-219 (Internal Quality A. Cell.)				1	1		1
68	A-220 (maintenance)	1			1			
69	A-221 (Sports Room)	2			6			1
70	A-222 (Classroom )				6	6		4
71	A-223 (Classroom)				0	6		5
72	A-224 (Database Laboratory)	2			0	6		6
73	A-225 (Artificial Intelligence Laboratory)				0	6		5



	<b>Admin Building (Third Floor)</b>				0			
74	A-301 (Class Room)				3	2		4
75	A-302 (Class Room)	1			2	2		5
76	A-303 (Toilets)				28			
77	A-304 (faculty Office)				9			1
78	A-305 (Classroom)				4	4		4
79	A-306 (faculty Office)	8			2	10		11
80	A-307 (Seminar Hall)				30	8		13
81	A-308 (Tutorial Room)				2			1
82	A-309 (Student Association)				0	3		6
83	A-310 (Hood and Dept. Office)				4			1
84	A-311 (Faculty Room)				2	1		1
85	A-312 (Stationery Store & Reprographic Centre)				1			
86	A-313 (NSS)				0	1		1
87	A-314 (Classroom)				28	6		4
88	A-315 (Classroom)				24	6		4
89	A-316 (Operating Systems Laboratory)				8	2		6
90	A-317 (Digital Electronics & Microprocessor			15	30	2		4



	Laboratory)							
91	W-1 (Workshop)			35	0	2		5
92	S-001 (Security)			3	0			2
93	(DG and Pump rooms )			22	0			
	<b>Buiding C</b>				0			
94	C-01 (Reception Area)				0	2		
95	C-02 (A) & (B) (Cafeteria Dining)				8	13		30
96	C-03 (Cafeteria Kitchen)	6			0	10		12
97	C-04 /5 / 6 (Toilets)			16	8			
98	C -7 (Girls Common Room )				0	8		4
99	C- 8 (Boyes Common Room)				0	8		4
100	C- 9 (Physica Lab)				0	8		4
101	C -10 (C.C. IT )				0	8		4
102	C-11 (Library and Reading Room)				0	28		26
103	C-12 (Class Room)				8	3		4
104	C-13 (Toilets)				15			
105	C-14 (Applied Chemistry Lab.)				0	3		4
106	C-15 (Class Room)				0	3		4
107	C-16 (Class Room)				0	3		4
108	C-17 (Class Room)				0	4		6
109	C-18 (Basic				0	3		3




	Mechanical Engg.)							
110	C-19 (Basic Civil Engg.)				0	4		3
111	<b>Takshshila Hostel</b>	60	7		71			54
112	<b>Nalanda Hostel</b>	421	6		709		50	423
113	<b>Mithila Hostel</b>	490	8		696		112	483
114	<b>Vikramshila Hostel</b>	414	3	0	789		100	411
		<b>1474</b>	<b>24</b>	<b>102</b>	<b>2888</b>	<b>373</b>	<b>272</b>	<b>1721</b>

Apart from above load, the school has pumps, Packaged ACs, CFLs and LED focus street lights on streets and grounds. Individual fitting wise load is as under.

Table No 2.2: Equipment wise Connected Load

No	Equipment	Qty	Load, W/Unit	Load, kW
1	Ceiling Fan	1721	65	111.9
2	FTL 40W	18	40	0.7
3	LED tube-20 W	1474	20	29.5
4	CFL	24	24	0.6
5	Led Sq. light (36 W)	102	36	3.7
6	Led lamp (9W)	2888	9	26.0
7	Led lamp (22W)	373	22	8.2
8	LED-20W	272	20	5.4
9	AC-New (2 TR)	2	2450	4.9
10	Package AC (16TR, 8.5TR)			30.0
11	Pumps 3HP (4nos), no of 5HP (5 nos), 7.5HP (5 nos),			56.2
12	LED street lights	45	50	2.3
	<b>Total</b>			<b>279.4</b>

Data can be represented in terms of PIE chart as under,



**Figure 2.1: Distribution of connected load.**




### 3. Study of Electrical Energy Consumption

In this chapter, electricity bills are studied for the analysis of electrical energy consumption.

**Table no 3.1: Summary of electricity bills**


No	Month	Energy (kWh)	Bill Amount (Rs)
1	Jun-23	69,774	10,53,884
2	May-23	73,949	11,08,659
3	Apr-23	70,050	10,74,846
4	Mar-23	92,567	13,68,986
5	Feb-23	72,850	11,03,557
6	Jan-23	81,062	12,18,237
7	Dec-22	87,956	13,10,532
8	Nov-22	81,688	12,27,027
9	Oct-22	81,558	12,36,824
10	Sep-22	95,329	14,21,582
11	Aug-22	90,002	13,37,242
12	Jul-22	84,481	12,62,260
	<b>Total</b>	<b>9,81,266</b>	<b>1,47,23,636</b>

Variation in energy consumption is as follows,



**Figure 3.1: Month wise energy consumption**

Monthly variation in electricity bill is as follows,



**Figure 3.2: Month wise electricity bill**

Key observations of electricity bill are as follows,

**Table no 3.2: Key observations**

Sr no	Parameter	Energy consumed, (Units)	CO2 Emission (MT)
1	Maximum	95,329	76.26
2	Minimum	69,774	55.82
3	Average	81,772	65.42
4	Total	9,81,266	785.01

## 4. Carbon Foot printing

1. A **Carbon Foot print** is defined as the Total Greenhouse Gas emissions (CO<sub>2</sub> emissions), emitted due to various activities. In this we compute the emissions of Carbon-Di-Oxide, by usage of the various form of Electrical Energy used by the College for performing its day to day activities

### 2. Basis for computation of CO<sub>2</sub> Emissions:

The basis of Calculation for CO<sub>2</sub> emissions due to Electrical Energy is as under

- 1 Unit (kWh) of Electrical Energy releases **0.8 Kg of CO<sub>2</sub>** into atmosphere.

Based on the above Data we compute the CO<sub>2</sub> emissions which are being released in to the atmosphere by the College due to its Day to Day operations


We herewith furnish the details of various forms of Energy consumption as under

**Table 4.1: Month wise Consumption of Electrical Energy & CO<sub>2</sub> Emissions**

No	Month	Energy Consumed, kWh	CO <sub>2</sub> Emissions, MT
1	Jun-23	69,774	55.82
2	May-23	73,949	59.16
3	Apr-23	70,050	56.04
4	Mar-23	92,567	74.05
5	Feb-23	72,850	58.28
6	Jan-23	81,062	64.85
7	Dec-22	87,956	70.36
8	Nov-22	81,688	65.35
9	Oct-22	81,558	65.25
10	Sep-22	95,329	76.26
11	Aug-22	90,002	72.00
12	Jul-22	84,481	67.58
	<b>Total</b>	<b>9,81,266</b>	<b>785.01</b>



In the following Chart we present the CO2 emissions due to usage of Electrical Energy.



**Figure 4.1: Month wise CO2 Emission**

## **5. Study of utilities**

### **5.1 Study of Lighting**

In the facility, the lighting system can be divided mainly in to parts, indoor lighting and outdoor lighting. There are 18 FTL fittings with Electronic/ magnetic chokes, 1474 LED tubes 272 LED passage tubes, 24 CFLs, 102 no of LED square lights (36W), 2888 no of LED lamps (9W) and 373 no of LED lamps (22W) in indoor lightings. It is recommended to install the 20 W LED Tube light fittings in place of old T-8 fittings. There are 17 number of CFL street lights and 45 No of LED street lights.

### **5.2 Air-conditioners**

In the facility, there are about 02 Nos. of 2 Tr star rated Air-conditioners. Also, in the facility there are package ACs with 8.5Tr and 16 Tr respectively.

### **5.3 Ceiling Fans**

At building facility, there are about 1721 Nos Old Ceiling Fans, which consumed about 65 W of Electrical Energy. It is recommended to replace these old Fans with BEE STAR Rated Ceiling Fans.

### **5.4 Water Pumps**

There are 4 no of 3HP capacity , 5 no of 5HP capacity and 5 nos of 7.5HP capacity pumps.



## 6. Study of usage of alternate energy

In this Chapter, we compute the percentage of Usage of Alternate/Renewable Energy to Annual Energy Requirement of the College. The College has installed Roof Top Solar PV System. The Installed Capacity of Solar PV Plant is 7 kWp. Also, college has installed 7 nos of solar thermal hot water systems with 600 liters capacity each. Total installed solar thermal hot water capacity is 4200 liters.

**Table 6.1: Computation of % Usage of Alternate Energy to Annual Energy Requirement**

No	Particulars	Value	Unit
1	Annual Energy Purchased from MSEDCL	981,266	kWh/Annum
2	Energy Generated by Roof Top Solar PV System	10,500	kWh/Annum
3	Total Energy Requirement of College	991,766	kWh/Annum
4	% of Usage of Alternate Energy to Annual Energy Requirement	1.05	%



**Figure 6.1: Photograph of Solar PV plant**



**Figure 6.2 :** Photograph of solar thermal hot water system

## 7. Study of usage of LED lighting

In this chapter we study the lighting system of college and compute the percentage of total load catered by LED lighting.

**Table 7.1: Total lighting load**

No	Particulars	Qty	Load, W/Unit	Load, kW
1	F T L-40 W	18	40	0.72
2	CFL	24	24	0.576
	<b>LED lighting load</b>			
1	LED passage tube	272	20	5.44
2	LED tube light	1474	20	29.48
3	Led Sq. light (36 W)	102	36	3.672
4	Led lamp (9W)	1055	9	9.495
5	Led lamp (22W)	373	22	8.206
6	LED street lights	30	35	1.05
	<b>Total LED lighting load</b>			<b>57.343</b>
	<b>Total Lighting load</b>			<b>58.639</b>

It can be seen that out of total lighting load 98% load is LED lighting load.



## 8. Energy conservation proposals

### 8.1 Replacement of old fans with STAR Rated fans

During the Audit, it was observed that there are 1721 no of fans. It is recommended to replace these old fans with STAR Rated fans.

In the following Table, we present the savings, investment required & payback analysis.

No	Particulars	Value	Unit
1	Present Qty of Old Ceiling Fan fittings	1721	Nos
2	Energy Demand of Old Ceiling Fan fitting	65	W/Unit
3	Energy Demand of STAR Rated Fan	52	W/Unit
4	Reduction in demad	13	W/Unit
5	Average Daily Usage period	4	Hrs/Day
6	Daily saving in Energy	89.492	kWh/Day
7	Annual Working Days	250	Nos
8	Annual Energy Saving possible	22373	kWh/Annum
9	Rate of Electrical Energy	11	Rs/kWh
10	Annual Monetary saving	246103	Rs/Annum
11	Cost of STAR Rated Ceiling Fan	2174	Rs/unit
12	Investment required	3741454	Rs lump sum
13	Simple Payback period	182	Months

## 8.2 Installation of 200kW Solar PV panel

It is recommended to install 200 kW solar PV panel. In the following Table, we present the savings, investment required & payback analysis.

No	Particulars	Value	Unit
1	Installation of 200kW PV unit	200	kW
2	Energy saving	300,000	kWh/Annum
3	Rate of electrical energy	11	Rs
4	Annual monetary savings	33,00,000	Rs/ Annum
5	Investment required	100,00,000	Rs lump sum
6	Simple payback period	36	Months

### 8.3 Summary of Savings

No	Recommendation	Annual Saving potential, kWh/Annum	Annual Monetary Gain, Rs.	Investment Required, Rs.	Payback period, Months
1	Replacement of 1721 Nos Old Ceiling Fans with STAR rating fans	22,373	246,103	3,741,454	182
2	Installation of 200kW grid connected PV panel	300,000	3,300,000	10,000,000	36
	<b>Total</b>	<b>322,373</b>	<b>3,546,103</b>	<b>13,741,454</b>	<b>47</b>



